



**TM 2013-10**

## **Clustered Toilet Rooms**

**Effective Date:** June 1, 2013  
**2012 TAS Reference:** 213.2, Exception 4

---

Based on information received from the U.S. Access Board, TAS 213.2, Exception 4 does **not** apply to multiple single user *bathing or shower rooms*; therefore, this Exception is applicable only to multiple single user toilet rooms clustered at a single location.

The phrase "*for each use*" in TAS 213.2, Exception 4 refers to the use of the toilet room by different sexes, age groups, designated users or purposes based on TAS 201.1(ii). For example, employee and public toilet rooms are two different uses and toilet rooms provided for males, females, and children are three different uses.

These clarifications do not constitute a substantive change to the compliance requirements of TAS 213.2, Exception 4.